

γ Range: 0 - 180DEG  
 γ Interval: 1.0DEG  
 Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
 Humidity: 49.1%  
 Test Distance:1.900m [K=1.1188]  
 Remarks:

## ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

$\gamma$	C0	C45	C90	C135	C180	C225	C270	C315	$\gamma$	$\Phi$ zone	$\Phi$ total	%lum, lamp
10	219.6	216.9	213.1	210.1	210.3	212.7	216.1	218.8	0- 10	20.69	20.69	3.38,3.38
20	211.1	206.2	199.0	193.7	193.6	198.3	204.7	210.0	10- 20	59.04	79.73	13,13
30	194.7	188.1	178.1	170.9	170.4	177.0	185.9	193.4	20- 30	88.89	168.6	27.5,27.5
40	171.7	163.8	151.3	142.5	141.8	150.1	161.0	170.3	30- 40	106.3	275.0	44.9,44.9
50	143.3	134.7	120.3	110.1	109.1	118.7	131.3	142.0	40- 50	109.4	384.3	62.7,62.7
60	110.7	101.6	85.81	75.05	73.82	84.16	97.87	109.6	50- 60	97.89	482.2	78.7,78.7
70	75.93	66.41	50.65	39.81	38.82	48.61	62.63	74.68	60- 70	73.94	556.2	90.7,90.7
80	40.91	32.15	18.77	10.10	9.132	16.77	28.67	39.27	70- 80	42.53	598.7	97.7,97.7
90	10.88	4.874	0.0075	0.0132	0.0000	0.0021	2.158	9.973	80- 90	13.27	612.0	99.8,99.8
100	0.0090	0.0130	0.0355	0.0401	0.0109	0.0116	0.0036	0.0015	90-100	0.7493	612.7	99.9,99.9
110	0.0178	0.0224	0.0482	0.0520	0.0289	0.0269	0.0166	0.0126	100-110	0.0238	612.7	100,100
120	0.0241	0.0335	0.0593	0.0738	0.0403	0.0443	0.0306	0.0273	110-120	0.0335	612.8	100,100
130	0.0513	0.0633	0.0853	0.0980	0.0715	0.0589	0.0415	0.0403	120-130	0.0460	612.8	100,100
140	0.0853	0.0962	0.1142	0.1236	0.0822	0.0717	0.0530	0.0560	130-140	0.0574	612.9	100,100
150	0.1133	0.1209	0.1354	0.1411	0.0973	0.0895	0.0807	0.0757	140-150	0.0606	612.9	100,100
160	0.1329	0.1371	0.1457	0.1486	0.1098	0.1037	0.0985	0.0962	150-160	0.0532	613.0	100,100
170	0.1311	0.1329	0.1343	0.1347	0.0784	0.1004	0.0771	0.0937	160-170	0.0333	613.0	100,100
180	0.0970	0.1128	0.1113	0.1121	0.1149	0.1133	0.1123	0.1124	170-180	0.0102	613.0	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 330.19 lm

%lum = 53.9%

%lamp = 53.9%

Conical surface Flux(120deg): 482.21 lm

%lum = 78.7%


%lamp = 78.7%

C Range: 0 - 360DEG  
 C Interval: 15.0DEG  
 Test Speed: HIGH  
 Temperature: 25.4DEG  
 Operators:  
 Test Date:2018-03-05

$\gamma$  Range: 0 - 180DEG  
 $\gamma$  Interval: 1.0DEG  
 Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
 Humidity: 49.1%  
 Test Distance:1.900m [K=1.1188]  
 Remarks:

## LUMINANCE LIMITATION CURVES

Test:U:120.150V I:0.0893A P:9.970W PF:0.9292 Freq:60.00Hz Lamp Flux:613.03x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	8444	2021
80	7012	3217
75	6699	3903
70	6607	4408
65	6583	4802
60	6591	5108
55	6614	5356
50	6637	5570
45	6658	5738

C Range: 0 - 360DEG  
C Interval: 15.0DEG  
Test Speed: HIGH  
Temperature: 25.4DEG  
Operators:  
Test Date:2018-03-05

$\gamma$  Range: 0 - 180DEG  
 $\gamma$  Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
Humidity: 49.1%  
Test Distance:1.900m [K=1.1188]  
Remarks:

### WEC AND CCEC

Test:U:120.150V I:0.0893A P:9.970W PF:0.9292 Freq:60.00Hz Lamp Flux:613.03x1 lm								
NAME:			TYPE:			WEIGHT:		
SPEC.:			DIM.:			SERIAL No.:		
MFR.:			SUR.:			Shielding Angle:		

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)										
0.0																	
1.0	.311	.177	.056	.304	.174	.055	.291	.167	.053	.279	.161	.052	.267	.155	.050		
2.0	.292	.160	.049	.286	.157	.048	.274	.152	.047	.263	.147	.046	.253	.143	.045		
3.0	.270	.144	.043	.264	.141	.043	.254	.138	.042	.244	.134	.041	.235	.130	.040		
4.0	.249	.129	.038	.244	.128	.038	.235	.124	.037	.226	.121	.037	.218	.118	.036		
5.0	.230	.117	.034	.226	.116	.034	.217	.113	.033	.210	.111	.033	.203	.108	.033		
6.0	.213	.107	.031	.209	.106	.030	.202	.104	.030	.195	.101	.030	.189	.099	.030		
7.0	.198	.098	.028	.195	.097	.028	.188	.095	.027	.182	.093	.027	.177	.092	.027		
8.0	.185	.091	.025	.182	.090	.025	.176	.088	.025	.171	.087	.025	.166	.085	.025		
9.0	.174	.084	.023	.171	.083	.023	.166	.082	.023	.161	.081	.023	.156	.079	.023		
10.0	.163	.078	.022	.161	.078	.022	.156	.076	.022	.152	.075	.021	.147	.074	.021		

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.192	.192	.192	.164	.164	.164	.112	.112	.112	.064	.064	.064	.021	.021	.021	
1.0	.182	.157	.136	.156	.135	.117	.106	.093	.081	.061	.054	.047	.020	.017	.015	
2.0	.174	.133	.099	.149	.115	.086	.102	.079	.060	.059	.046	.035	.019	.015	.011	
3.0	.166	.116	.076	.142	.100	.066	.098	.069	.046	.056	.040	.027	.018	.013	.009	
4.0	.158	.102	.060	.136	.088	.052	.093	.062	.037	.054	.036	.022	.017	.012	.007	
5.0	.151	.092	.049	.129	.080	.042	.089	.056	.030	.052	.033	.018	.017	.011	.006	
6.0	.143	.084	.041	.123	.072	.035	.085	.051	.025	.049	.030	.015	.016	.010	.005	
7.0	.137	.077	.035	.118	.066	.030	.081	.047	.021	.047	.027	.013	.015	.009	.004	
8.0	.130	.071	.030	.112	.061	.026	.078	.043	.019	.045	.025	.011	.015	.008	.004	
9.0	.124	.066	.027	.107	.057	.023	.074	.040	.016	.043	.024	.010	.014	.008	.003	
10.0	.118	.062	.024	.102	.054	.021	.071	.038	.015	.041	.022	.009	.013	.007	.003	

C Range: 0 - 360DEG  
C Interval: 15.0DEG  
Test Speed: HIGH  
Temperature: 25.4DEG  
Operators:  
Test Date:2018-03-05

γ Range: 0 - 180DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
Humidity: 49.1%  
Test Distance:1.900m [K=1.1188]  
Remarks:

UGR(Unified Glare Rating) Table

Test:U:120.150V I:0.0893A P:9.970W PF:0.9292 Freq:60.00Hz Lamp Flux:613.03x1 lm											
NAME:					TYPE:			WEIGHT:			
SPEC.:					DIM.:			SERIAL No.:			
MFR.:					SUR.:			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions	Viewed crosswise					Viewed endwise					
x = 2H y = 2H	21.5	23.0	21.8	23.2	23.4	20.6	22.1	20.8	22.3	22.5	
	3H	23.3	24.7	23.6	25.0	25.2	21.9	23.3	22.2	23.6	23.8
	4H	24.1	25.5	24.4	25.7	26.0	22.4	23.8	22.8	24.0	24.3
	6H	24.8	26.1	25.2	26.4	26.7	22.8	24.0	23.1	24.3	24.6
	8H	25.1	26.4	25.5	26.6	26.9	22.8	24.0	23.2	24.3	24.6
	12H	25.4	26.6	25.8	26.9	27.2	22.9	24.0	23.2	24.3	24.6
4H	2H	22.1	23.4	22.4	23.7	23.9	21.3	22.7	21.7	22.9	23.2
	3H	24.1	25.2	24.4	25.5	25.9	22.9	24.1	23.3	24.4	24.7
	4H	25.0	26.1	25.4	26.4	26.8	23.6	24.6	24.0	25.0	25.3
	6H	25.9	26.9	26.3	27.2	27.6	24.0	25.0	24.4	25.3	25.7
	8H	26.3	27.2	26.7	27.6	28.0	24.2	25.0	24.6	25.4	25.8
	12H	26.7	27.5	27.1	27.9	28.3	24.2	25.0	24.6	25.4	25.8
8H	4H	25.3	26.2	25.7	26.5	26.9	24.0	24.9	24.4	25.3	25.7
	6H	26.4	27.1	26.8	27.5	27.9	24.7	25.4	25.1	25.8	26.2
	8H	26.9	27.5	27.3	28.0	28.4	24.9	25.5	25.3	26.0	26.4
	12H	27.4	28.0	27.9	28.4	28.9	25.0	25.6	25.5	26.0	26.5
12H	4H	25.3	26.1	25.7	26.5	26.9	24.1	24.9	24.5	25.3	25.7
	6H	26.4	27.1	26.9	27.5	28.0	24.8	25.5	25.3	25.9	26.3
	8H	27.0	27.6	27.5	28.0	28.5	25.1	25.6	25.6	26.1	26.6
Variations with the observer position at spacings:											
S = 1.0H	+ 0.1 / - 0.2					+ 0.2 / - 0.2					
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.4					
2.0H	+ 0.1 / - 0.3					+ 0.2 / - 0.4					

CIE Pub.117, 613.0 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -1.7)


C Range: 0 - 360DEG  
C Interval: 15.0DEG  
Test Speed: HIGH  
Temperature: 25.4DEG  
Operators:  
Test Date:2018-03-05

γ Range: 0 - 180DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
Humidity: 49.1%  
Test Distance:1.900m [K=1.1188]  
Remarks:

γ Range: 0 - 180DEG  
 γ Interval: 1.0DEG  
 Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
 Humidity: 49.1%  
 Test Distance:1.900m [K=1.1188]  
 Remarks:

## ISOCANDELA DIAGRAM

Test:U:120.150V I:0.0893A P:9.970W PF:0.9292 Freq:60.00Hz Lamp Flux:613.03x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:




C Range: 0 - 360DEG  
C Interval: 15.0DEG  
Test Speed: HIGH  
Temperature: 25.4DEG  
Operators:  
Test Date:2018-03-05

$\gamma$  Range: 0 - 180DEG  
 $\gamma$  Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
Humidity: 49.1%  
Test Distance:1.900m [K=1.1188]  
Remarks:

### AAI Figure

Test:U:120.150V I:0.0893A P:9.970W PF:0.9292 Freq:60.00Hz Lamp Flux:613.03x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.


C Range: 0 - 360DEG  
C Interval: 15.0DEG  
Test Speed: HIGH  
Temperature: 25.4DEG  
Operators:  
Test Date:2018-03-05

γ Range: 0 - 180DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
Humidity: 49.1%  
Test Distance:1.900m [K=1.1188]  
Remarks:



## ISOLUX DIAGRAM


Test:U:120.150V I:0.0893A P:9.970W PF:0.9292 Freq:60.00Hz Lamp Flux:613.03x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:



C Range: 0 - 360DEG  
C Interval: 15.0DEG  
Test Speed: HIGH  
Temperature: 25.4DEG  
Operators:  
Test Date:2018-03-05

γ Range: 0 - 180DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
Humidity: 49.1%  
Test Distance:1.900m [K=1.1188]  
Remarks:

## Planar Illuminance Curve



C Range: 0 - 360DEG  
C Interval: 15.0DEG  
Test Speed: HIGH  
Temperature: 25.4DEG  
Operators:  
Test Date: 2018-03-05

$\gamma$  Range: 0 - 180DEG  
 $\gamma$  Interval: 1.0DEG  
Test System: EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
Humidity: 49.1%  
Test Distance: 1.900m [K=1.1188]  
Remarks:

## LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:120.150V I:0.0893A P:9.970W PF:0.9292 Freq:60.00Hz Lamp Flux:613.03x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: cd

C (DEG) γ (DEG)	0	15	30	45	60	75	90	105	120	135	150	165	180	195	210	225	240	255	270
0	219	219	219	219	219	219	219	219	219	219	219	219	219	219	219	219	219	219	219
5	221	220	220	219	218	218	217	216	216	216	215	215	216	216	216	217	218	218	219
10	220	219	218	217	216	214	213	212	211	210	210	210	210	211	212	213	214	215	216
15	216	215	214	213	211	209	207	205	204	203	202	202	203	204	205	206	208	210	211
20	211	210	208	206	204	201	199	197	195	194	193	193	194	194	196	198	200	203	205
25	204	202	200	198	195	192	189	187	185	183	182	182	183	184	186	188	191	194	196
30	195	193	191	188	185	181	178	175	173	171	170	169	170	172	174	177	180	183	186
35	184	182	180	177	173	169	165	162	159	157	156	155	157	158	161	164	167	171	174
40	172	170	167	164	160	155	151	148	145	142	141	140	142	144	147	150	154	157	161
45	158	156	154	150	145	140	136	133	129	127	125	124	126	128	131	135	139	143	147
50	143	142	139	135	130	125	120	116	113	110	108	108	109	111	115	119	123	127	131
55	127	126	123	119	113	108	103	99.0	95.6	92.7	90.9	90.4	91.6	94.0	97.5	102	106	110	115
60	111	109	106	102	96.3	90.9	85.8	81.5	77.9	75.0	73.2	72.8	73.8	76.4	80.0	84.2	88.4	93.1	97.9
65	93.5	91.7	88.7	84.1	78.8	73.3	68.2	63.7	60.1	57.0	55.3	54.8	56.0	58.4	62.0	66.3	70.6	75.4	80.3
70	75.9	74.1	71.0	66.4	61.1	55.7	50.7	46.2	42.7	39.8	38.1	37.7	38.8	41.1	44.6	48.6	53.0	57.7	62.6
75	58.3	56.2	53.6	48.9	43.8	38.7	33.9	29.7	26.2	23.7	22.1	21.8	22.9	24.9	28.0	31.7	35.9	40.4	45.1
80	40.9	39.1	36.2	32.1	27.6	23.1	18.8	15.1	12.3	10.1	8.66	8.26	9.13	11.1	13.8	16.8	20.4	24.4	28.7
85	24.7	23.1	20.5	17.2	13.3	9.46	5.92	2.81	0.21	0.01	0.01	0.01	0.01	0.00	0.00	0.68	4.40	7.39	10.8
90	10.9	9.54	7.62	4.87	0.85	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.02	2.16
95	0.12	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00
100	0.01	0.01	0.01	0.01	0.01	0.02	0.04	0.05	0.06	0.04	0.02	0.02	0.01	0.01	0.01	0.01	0.02	0.01	0.00
105	0.01	0.01	0.02	0.02	0.02	0.03	0.04	0.05	0.06	0.05	0.03	0.03	0.02	0.02	0.03	0.02	0.02	0.02	0.01
110	0.02	0.02	0.02	0.02	0.03	0.04	0.05	0.06	0.06	0.05	0.03	0.03	0.03	0.03	0.04	0.03	0.03	0.03	0.02
115	0.02	0.02	0.02	0.03	0.03	0.04	0.05	0.06	0.07	0.04	0.03	0.03	0.03	0.03	0.04	0.03	0.03	0.03	0.02
120	0.02	0.03	0.03	0.03	0.04	0.05	0.06	0.07	0.07	0.07	0.04	0.04	0.04	0.05	0.05	0.04	0.04	0.04	0.03
125	0.04	0.04	0.04	0.05	0.05	0.06	0.07	0.08	0.08	0.08	0.08	0.05	0.05	0.06	0.06	0.05	0.04	0.04	0.04
130	0.05	0.05	0.06	0.06	0.07	0.08	0.09	0.09	0.10	0.10	0.08	0.09	0.07	0.07	0.06	0.06	0.05	0.05	0.04
135	0.07	0.07	0.08	0.08	0.09	0.09	0.10	0.11	0.11	0.11	0.11	0.10	0.06	0.07	0.07	0.06	0.06	0.06	0.05
140	0.09	0.09	0.09	0.10	0.10	0.11	0.11	0.12	0.12	0.12	0.12	0.12	0.08	0.08	0.08	0.07	0.07	0.06	0.05
145	0.10	0.10	0.11	0.11	0.12	0.12	0.13	0.13	0.13	0.14	0.13	0.13	0.09	0.09	0.08	0.08	0.08	0.07	0.06
150	0.11	0.12	0.12	0.12	0.13	0.13	0.14	0.14	0.14	0.14	0.14	0.14	0.10	0.10	0.09	0.09	0.09	0.08	0.08
155	0.13	0.13	0.13	0.13	0.14	0.14	0.14	0.15	0.15	0.15	0.15	0.15	0.11	0.10	0.10	0.10	0.09	0.09	0.09
160	0.13	0.13	0.14	0.14	0.12	0.14	0.15	0.15	0.15	0.15	0.15	0.13	0.11	0.11	0.11	0.10	0.10	0.10	0.10
165	0.13	0.14	0.14	0.14	0.12	0.14	0.14	0.14	0.14	0.14	0.14	0.12	0.09	0.11	0.11	0.11	0.10	0.10	0.10
170	0.13	0.13	0.13	0.13	0.13	0.11	0.13	0.13	0.13	0.13	0.13	0.11	0.08	0.08	0.10	0.10	0.10	0.10	0.08
175	0.13	0.13	0.13	0.13	0.13	0.12	0.11	0.11	0.11	0.11	0.11	0.11	0.09	0.09	0.09	0.09	0.09	0.08	0.08
180	0.10	0.10	0.10	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11

C Range: 0 - 360DEG  
C Interval: 15.0DEG  
Test Speed: HIGH  
Temperature: 25.4DEG  
Operators:  
Test Date:2018-03-05

γ Range: 0 - 180DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
Humidity: 49.1%  
Test Distance:1.900m [K=1.1188]  
Remarks:

## LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:120.150V I:0.0893A P:9.970W PF:0.9292 Freq:60.00Hz Lamp Flux:613.03x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: cd

C (DEG) γ (DEG)	285	300	315	330	345														
0	219	219	219	219	219														
5	219	220	220	220	220														
10	217	218	219	219	219														
15	213	214	215	216	216														
20	207	209	210	211	211														
25	199	201	203	203	204														
30	189	192	193	194	195														
35	178	181	183	184	184														
40	165	168	170	171	172														
45	151	154	157	158	158														
50	136	140	142	143	144														
55	119	124	126	128	128														
60	103	107	110	111	111														
65	85.2	89.5	92.3	93.7	94.0														
70	67.5	71.8	74.7	76.1	76.4														
75	49.7	53.8	56.7	58.2	58.6														
80	32.8	36.5	39.3	40.9	41.3														
85	17.7	20.9	23.2	24.8	25.3														
90	5.50	8.11	9.97	11.3	11.5														
95	0.00	0.00	0.01	0.26	0.32														
100	0.00	0.00	0.00	0.00	0.00														
105	0.01	0.01	0.01	0.01	0.01														
110	0.02	0.01	0.01	0.01	0.01														
115	0.02	0.02	0.02	0.02	0.02														
120	0.03	0.03	0.03	0.03	0.03														
125	0.04	0.04	0.03	0.03	0.03														
130	0.04	0.04	0.04	0.04	0.04														
135	0.05	0.05	0.05	0.05	0.05														
140	0.06	0.06	0.06	0.05	0.05														
145	0.07	0.07	0.07	0.06	0.07														
150	0.08	0.08	0.08	0.08	0.08														
155	0.08	0.09	0.09	0.09	0.09														
160	0.08	0.10	0.10	0.10	0.09														
165	0.08	0.10	0.10	0.10	0.10														
170	0.08	0.09	0.09	0.10	0.10														
175	0.10	0.10	0.10	0.10	0.10														
180	0.11	0.11	0.11	0.11	0.11														

C Range: 0 - 360DEG  
C Interval: 15.0DEG  
Test Speed: HIGH  
Temperature: 25.4DEG  
Operators:  
Test Date:2018-03-05

γ Range: 0 - 180DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-R5000\_V2 SYSTEM V2.0.366  
Humidity: 49.1%  
Test Distance:1.900m [K=1.1188]  
Remarks: